

# TREATMENT PLANT REPORT

# 2008

	<b>MAXIMUM PARAMETERS ALOUDED BY CNA</b>	<b>JANUARY</b>	<b>FEBRUARY</b>	<b>MARCH</b>	<b>APRIL</b>
Fecal Coliforms (NMP/100ml)	240	<30	<30	<30	<30
Biochemical Oxygen Demand (mg/l) after sand filter	20	10.44	8.34	7.03	6.09
Total Suspended Solids (mg/l)	20	15	7.3	10	9.0
Greases and Oils (mg/l)	15	36.2	1.3	1.4	11.7
Residual Free Chlorine (mg/l)		8.0	8.0	8.0	1.5
Plant efficiency		95.42%	93.53%	94.37%	88%