

TREATMENT PLANT REPORT

2009

	MAXIMUM PARAMETERS ALLOWED BY CNA	DECEMBER
Fecal Coliforms (NMP/100ml)	240	<3
Biochemical Oxygen Demand (mg/l) after sand filter	20	1.98
Total Suspended Solids (mg/l)	20	5.7
Greases and Oils (mg/l)	15	1.3
Residual Free Chlorine (mg/l)		N/A
Plant efficiency		90.58%