

# TREATMENT PLANT REPORT

# 2007

|  | <b>MAXIMUM<br/>PARAMETERS<br/>ALOUDED BY<br/>CNA</b> | <b>JULY</b> | <b>AUG</b> | <b>SEPT</b> | <b>OCT</b> | <b>NOV</b> |
|--|--|-------------|------------|-------------|------------|------------|
| Fecal Coliforms<br>(NMP/100ml)                             | 240  | <30         | 150        | <30         | <30        | <30        |
| Biochemical Oxygen De-<br>mand (mg/l) after sand<br>filter | 20   | 29.60       | 6.20       | <1.98       | 25.33      | <1.98      |
| Total Suspended Solids<br>(mg/l)                           | 20   | 23          | 11         | 20          | 36         | 12         |
| Greases and Oils (mg/l)                                    | 15   | 38.6        | 5.8        | 18.8        | 17.50      | <1.3       |
| Residual Free Chlorine<br>(mg/l)                           |  | 1.0         | ND         | 12          | ND         | 4          |