

2
0
1
0

TREATMENT PLANT REPORT

PARAMETERS	MAXIMUM PARAMETERS ALLOWED BY CNA	MAY	JUNE
Fecal Coliforms (NMP/100ml)	240	<3	<3
Biochemical Oxygen Demand (mg/l) after sand filter	20	4.0	35.62
Total Suspended Solids (mg/l)	20	8.0	28
Greases and Oils (mg/l)	15	1.3	2.3
Residual Free Chlorine (mg/l)	-	N/A	N/A
Plant efficiency		90.11%	95.54%