

# TREATMENT PLANT REPORT

# 2007

	JAN	FEB	MARCH	APRIL	MAY	JUNE	JULY	AUG	SEPT	OCT
Fecal Coliforms (NMP/100ml)	<30	<30	930	<30	930	<30	<30	150	<30	<30
Biochemical Oxygen Demand (mg/l) after sand filter	1.98	6.87	12.20	14.20	17.95	18.25	29.60	6.20	<1.98	25.33
Total Suspended Solids (mg/l)	17.0	10.0	14.0	9.0	8.0	13	23	11	20	36
Greases and Oils (mg/l)	4.0	7.1	8.1	49.0	12.3	41.6	38.6	5.8	18.8	17.50
Residual Free Chlorine (mg/l)	2.0	2.0	ND	6.0	ND	4.0	1.0	ND	12	ND
<b>Plant Efficiency</b>	<b>99.15%</b>	<b>94.50%</b>	<b>92.25%</b>	<b>88.30%</b>	<b>91.65%</b>	<b>96.56%</b>	<b>97.82%</b>	<b>91.98%</b>	<b>96.95%</b>	<b>96.16%</b>