

TREATMENT PLANT REPORT

2008

	MAXIMUM PARAMETERS ALOUDED BY CNA	JANUARY	FEBRUARY	MARCH	APRIL	MAY
Fecal Coliforms (NMP/100ml)	240	<30	<30	<30	<30	<3
Biochemical Oxygen Demand (mg/l) after sand filter	20	10.44	8.34	7.03	6.09	4.56
Total Suspended Solids (mg/l)	20	15	7.3	10	9.0	14
Greases and Oils (mg/l)	15	36.2	1.3	1.4	11.7	<1.3
Residual Free Chlorine (mg/l)		8.0	8.0	8.0	1.5	8.0
Plant efficiency		95.42%	93.53%	94.37%	88%	92.50%