

TREATMENT PLANT REPORT

2007

	JANUARY	FEBRUARY	MARCH	APRIL	MAY	JUNE	JULY	AUGUST	SEPT.
Fecal Coliforms (NMP/100ml)	<30	<30	930	<30	930	<30	<30	150	<30
Biochemical Oxygen Demand (mg/l) after sand filter	1.98	6.87	12.20	14.20	17.95	18.25	29.60	6.20	<1.98
Total Suspended Solids (mg/l)	17.0	10.0	14.0	9.0	8.0	13	23	11	20
Greases and Oils (mg/l)	4.0	7.1	8.1	49.0	12.3	41.6	38.6	5.8	18.8
Residual Free Chlorine (mg/l)	2.0	2.0	ND	6.0	ND	4.0	1.0	ND	12
Plant Efficiency	99.15%	94.50%	92.25%	88.30%	91.65%	96.56%	97.82%	91.98%	96.95%